

ISIL İLETKENLİK DENEY SONUÇLARI

results of thermal conductivity test

Normal Dansite <i>Normal Density</i>	Isı İletkenlik Katsayısı [W.m ⁻¹ .K ⁻¹] <i>Thermal Conductivity Factor</i>	Termal Direnç Değeri [m ² .K/W] <i>Thermal Resistance Value</i>	Atıf Yapılan Standart <i>Referenced Standard</i>	Test Standartı <i>Test Standard</i>
16 kg/m ³	0,036641	1,405241	EN 13163:2008	EN 12667/EN 12939
20 kg/m ³	0,036641	1,365831	EN 13163:2008	EN 12667/EN 12939
26 kg/m ³	0,034518	1,430637	EN 13163:2008	EN 12667/EN 12939

